


NEW (910 797)



Special installation conditions must be considered when installing BLITZDUCTORconnect surge protective devices in intrinsically safe circuits. In accordance with EN 60079-11:2007 a minimum distance (thread measure) of ≥ 50 mm must be maintained between intrinsically and non-intrinsically safe circuits (connecting parts, e.g. terminals)! When using the Ex i partition of type PARTITION EXI, this distance is also maintained if the surge protective devices are arranged directly next to one other. Ideally suited for use in conjunction with DRC IRCM for condition monitoring of BCO modules (1 set = 2 pieces).



Type	
Part No.	910 797
Colour	blue
For mounting on	35 mm DIN rails acc. to EN 60715
Weight	
Customs tariff number (Comb. Nomenclature VAE)	
GTIN	
PU	